

# BUILDING RESEARCH INSTITUTE

## CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSAW  
tel, no. (22) 57 96 167, (22) 57 96 168, fax: (22) 57 96 295  
e-mail: certyfikacja@itb.pl, www.itb.pl

# CERTIFICATE OF COMPLIANCE

ITB-1668/W

Hereby it is confirmed that:

## Steel doors, AW DS, AW DS EI 30 and AW DS EI 60 and large steel doors AW DS EI 30 and AW DS EI 60

made in the form of single or double-leaf hinged doors, solid or partially glazed  
and with a defined class of fire resistance and smoke tightness

• **Fire resistance classes,**

acc. to PN-EN 13501-2+A1:2010 for the doors made acc. to section 1.2. and 1.3. AT-15-7413/2012:

- o EI<sub>2</sub>30 - applies to doors AW DS EI 30 and large size doors AW DS EI 30;
- o EI<sub>2</sub>60 - applies to doors AW DS EI 60 and large size doors AW DS EI 60.

• **Smoke tightness class,** acc. to PN-EN 13501-2+A1:2010 for the doors made acc. to section 1.2. AT-15-7413/2012:

- o S<sub>a</sub> and S<sub>m</sub> - applies to the doors AW DS EI 30 and AW DS EI 60 (with STADI L24/200S or Igloo DA1001 descending strip manufactured by DOMATIC).

marketed and manufactured by:

**„WIŚNIOWSKI" Sp. z o.o. S.K.A.**  
**33-311 Wielogłowy 153**

at the production plant:

**„WIŚNIOWSKI" Sp. z o.o. S.K.A.**  
**33-311 Wielogłowy 153**

meet the requirements defined in:

### The Technical Approval no. AT-15-7413/2012 + Annex no. 1

The manufacturer has implemented a system of factory production control and carries out tests on product samples taken at the production plant acc. to their testing plan.

The BRI Certification Department has completed the preliminary type tests and the preliminary audit at the production plant and of the factory production control; the BRI CD carries out continuous monitoring, assessment and acceptance of the factory production control.

This Certificate is a document required in the compliance assessment system 1 pursuant to the Regulation of Ministry of Infrastructure dated 11 August 2004 *on the method for declaring compliance of construction products and their identification with the construction mark* (Journal of Laws issue 198 item 2041 as amended).

The first issue of the Certificate of Compliance no. ITB-1668/W is dated 12/04/2008. This Certificate (updated on 08/02/2012 and 05/10/2012) shall only be used in reference to the products which meet the requirements of the aforementioned technical specification and expires on 24/09/2017, provided that the technical specification remains valid and the following are not subjected to significant modification: the product type, the conditions and site of manufacture, or the factory production control system.

MANAGER  
of Certification Department



Barbara Dobosz



Warsaw, 05/10/2012

DIRECTOR  
of the Building Research Institute



Jan Bobrowicz